



CSA INTERNATIONAL

Certificate of Compliance

Certificate: 1403550 (LR 5835-45)

Master Contract: 165016

Project: 1403550


Date Issued: February 10, 2003

Issued to: **Federal Signal Corp.**
2645 Federal Signal Dr.
University Park, IL 60466-3195
USA
Attention: Ms. Susan Wong

The products listed below are eligible to bear the CSA Mark shown



Issued by:


Joseph Kwong, P. Eng

Authorized by: 
Ray Fadavi, P. Eng., M.B.A.
Operations Manager

PRODUCTS

CLASS 4812 04 - SIGNAL APPLIANCES - Audible

Amplified speakers/audible signals, for indoor or outdoor use, (Enclosure 3R), Model ASHP, 24V dc, 0.55A or 120V, 50/60Hz, 0.28A; Model ASLP, 24V dc, 0.07A; Models 50GC and 50GCB, 24V, 50/60Hz, 0.22A or 24V dc, 0.07A or 120V, 50/60Hz, 0.033A; or 230/240V, 50/60Hz, 0.02A; Model 300D, 24V dc, 0.6A or 120V, 50/60Hz, 0.28A; Model 300GC, 24V, 50/60Hz, 1.25A or 24V dc, 0.55A or 48V dc, 0.35A or 120V, 50/60Hz, 0.27A or 240V, 50/60Hz, 0.12A; Model 302GC, 24V, 50/60Hz, 2.5A or 24V dc, 1.1A or 120V, 60Hz, 0.5A or 240V, 50/60Hz, 0.2A; Model 300, 250V dc, 0.072A.

Speakers, indoor or outdoor (Enclosure 3R), 25 or 70V ac, Models AM300, SPHP, 0.5, 1.0, 2.0, 7.0 and 15W power taps; AM302, 7, 15 and 30W power taps; indoor only, Models AMR4, AMS4, AM50, 0.25, 0.5, 1.0 and 2.0 power taps; AMM1, 25V, 1.0W.

Plug-in modules, Models TM-1 through -11, -11A, -12, -13, -33; TC-BL, -BP, -HL, -HN, -ST, -SW, -TW, -WL, -YP, -YW; UTM, UTC, PTCK25, PTCK70, AM25CK, AM70CK, CK25, CK70, 300CK, 300CKS, for use with amplified speakers.

APPLICABLE REQUIREMENTS

CSA Std C22.2 No. 205-M1983 - Signal Equipment