

# Certificate of Compliance

**Certificate:** 1542433

**Master Contract:** 224903

**Project:** 1542433

**Date Issued:** April 8, 2004


**Issued to:** Federal Signal Corporation  
2645 Federal Signal Dr  
University Park, IL 60466-3195  
U S A

**Attention:** Mr. Leonard Steinbeigle

*The products listed below are eligible to bear the CSA Mark shown*



**Issued by:** K. Atkins

**Authorized by:**   
Nick Alfano  
Operations Manager

## PRODUCTS

CLASS 4818 03 - SIGNAL APPLIANCES - Miscellaneous - For Hazardous Locations

Class I, Groups C and D; Class II, Groups E, F and G; Class III:

Fire alarm station Series MPEX conduit sizes  $\frac{3}{4}$  and 1 in rated 120V ac, 6A.

Fire alarm station Series MPEX conduit sizes  $\frac{1}{2}$  through 1-1/2 in., rated 12V ac, 6A

## APPLICABLE REQUIREMENTS

CSA Std C22.2 No. - 25-1966 - Enclosures for Use in Class II, Groups E, F and G Hazardous Locations

CSA Std C22.2 No. - 30-M1986 - Explosion-Proof Enclosures for Use in Class I Hazardous Locations

CSA Std C22.2 No. - 205-M1983 - Signal Equipment

**Certificate:** 1542433

**Master Contract:** 224903

**Project:** 1542433

**Date:** April 8, 2004

---

**MARKINGS**

Company's name and/or logo

CSA Monogram

Catalogue or model number

Hazardous location designation – Class I, Groups C and D; Class II, Groups E, F and G; Class III (or equivalent)

Electrical Rating 120V ac, 6A

Date code or serial number

The following bilingual caution/warning markings: "OPEN CIRCUITS BEFORE REMOVING COVER" and "OUVRIR LE CIRCUIT AVANT D'ENLEVER LE COUVERCLE" and "PERFORMANCE AS A FIRE-ALARM ACTUATOR HAS NOT BEEN EVALUATED BY CSA" and "L'APTITUDE DE CE PRODUIT A DECLENCHEUR L'ALARME – INCENDIE N'A PAS ETE VERIFIEE PAR A CSA" or equivalent.